








Detail Pos. 4, 5 / detail pos. 4, 5

Min./max. zul. Druck		Mantelraum	
Min./max. allow. pressure	(PS)	Inside of jacket	
Min./max. zul. Temperatur	(TS)		
Min./max. allow. temperature			
Prüfdruck	(PT)		
Test pressure			
Volumen	(V)		
Capacity			
Oberflächenbearbeitung		gebeizt und passiviert	
Surface treatment		pickled and passivated	
Werkstoff			
material			
Gewicht			
Weight			
Artikel-Nr.			
Article number			
Kategorie/Modul DGR 2014/68/EU			
Category/module PED 2014/68/EU			

10	Entlüftung / air vent	Rp 1"		DIN 2986		
9 (3x)	Sonde / probe	Rp 1/2"		DIN 2986		
8 (3x)	Thermometer / thermometer	Rp 1/2"		DIN 2986		
7	Mannlloch / man hole 400 / 480	400	10	RET	EPDM	
6	Warmwasser / hot water	Rp 2"		DIN 2986		
5	Ladevorlauf / heating flow	Rp 1 1/4"		DIN 2986		
4	Zirkulation / circulation	Rp 1 1/4"		DIN 2986		
3	Laderücklauf / heating return	Rp 1 1/4"		DIN 2986		
2	Kaltwasser / cold water	Rp 2"		DIN 2986		
1	Entleerung / drain	Rp 1 1/4"		DIN 2986		
Stutzen Nozzle	Benennung Denomination	DN	PN	Norm Standard	Dichtfläche Facing	Position Position
						Rohr- Dimension

Rev3	27.01.2025	Riedel	Whan	changes according customers request
Rev2	16.01.2025	Ehrentrauf	Whan	changes according customers request
Rev1	17.12.2024	Ehrentrauf	Whan	changes according customers request
Index	Datum/date	Gez./drawn	Gepr./appr.	Art der Änderung / Modification
	Datum/date	Name/name		
Gez. / drawn	13.12.2024	Ehrentrauf		
Gepr. / appr.	13.12.2024	Whan		

Warmwasserspeicher - Curve 2



Zeichnung Nr. / Drawing No.:	Projekt Nr. / Project No.:	Bestell Nr. / Order No.:	Maßstab / Scale	Blatt / sheet
22784-0 Rev3	P2400109	KST300	1:15	1/1