





Kippmaß: 2485

Min./max. zul. Druck (PS)
Min./max. allow. pressure (PS)
Min./max. zul. Temperatur (TS)
Min./max. allow. temperature (TS)
Prüfdruck (PT)
Test pressure (PT)
Volumen Capacity (V)
Oberflächenbearbeitung Surface treatment
Werkstoff material
Material
Gewicht Weight

Manterraum inside of jacket

Rohrraum inside of tubes

0 / 6

0 / 109

9

3000

gebeizt und passiviert pickled and passivated

14571 / 14404

450

Artikel-Nr. Article number
Kategorie/Modul DGRL 2014/68/EU Category/module PED 2014/68/EU

Art. 4. Abs. (3)

11	Thermometer	Rp 1/2"	DIN 2986			
10	Thermometer	Rp 1/2"	DIN 2986			
9	Thermometer	Rp 1/2"	DIN 2986			
8	Sonde	Rp 1/2"	DIN 2986			
7	Sonde	Rp 1/2"	DIN 2986			
6	Flanshschluss / flange connection	125 16	EN 1092-1/11			
5	Flanshschluss / flange connection	125 16	EN 1092-1/11			
4	Flanshschluss / flange connection	125 16	EN 1092-1/11			
3	Flanshschluss / flange connection	125 16	EN 1092-1/11			
2	Entlüftung	Rp 1"	DIN 2986			
1	Entlüftung	Rp 1 1/4"	DIN 2986			
	Stutzen	Benennung	DN	PN	Dichtfläche	Position
	Nozle	Denomination	Standard	Facing	Position	Rohtabmessung Dimension

Index Datum/date Gez./drawn/Gepr./appr		Kennwert/Subject		Art der Änderung / Modification	
Datum/date Name/name					
Gez. / drawn 10.12.2025 Altmanshofer					
Gepr. / appr. 10.12.2025 Wilken					
Benennung / Designation : Wasserspeicher / storage tank Typ RET 3000 special					
Zeichnung Nr. / Drawing No. : 23407-0		Projekt Nr. / Project No. : P2500860		Bestell-Nr. / Order No. : KST300/123853	
				Maßstab / Scale 1:15	
				Blatt / sheet 1/X	
				Stand/as per: 10.12.2025	