



Kippsmaß: 24,85

Min./max zul. Druck	(PS)	0 / 6	Min./max zul. Temperature	(TS)	0 / 109
Min./max allow. pressure	(PS)	0 / 6	Min./max. allow. temperature	(TS)	0 / 109
Min./max zul. Temperature	(TS)	0 / 109	Prüfdruck	(PT)	9
Min./max. allow. temperature	(TS)	0 / 109	Test pressure	(PT)	9
Prüfdruck	(PT)	9	Volumen	(V)	3000
Test pressure	(PT)	9	Capacity	(V)	3000
Volumen	(V)	3000	Oberflächenbearbeitung		gebeizt und passiviert
Capacity	(V)	3000	Surface treatment		pichled and passivated
Werkstoff		1.4571 / 1.4404	Artikel-Nr.		
material		1.4571 / 1.4404	Article number		
Gewicht		450	Kategorie/Modul DGRL 2014/68/EU		
Weight		450	Category/module PED 2014/68/EU		
Artikel-Nr.			Art. 4. Abs. (3)		
Article number					

10	Thermometer / thermometer	Rp 1/2"	DIN 2986		
9	Thermometer / thermometer	Rp 1/2"	DIN 2986		
8	Thermometer / thermometer	Rp 1/2"	DIN 2986		
7	Sonde / probe	Rp 1/2"	DIN 2986		
6	Sonde / probe	Rp 1/2"	DIN 2986		
5	Flanschsanschluss / flange connection	125	16	EN 1092-1/11	
4	Flanschsanschluss / flange connection	125	16	EN 1092-1/11	
3	Flanschsanschluss / flange connection	100	16	EN 1092-1/11	
2	Entlüftung / vent	Rp 1/2"	DIN 2986		
1	Entlüftung / drain	Rp 3/4"	DIN 2986		
Stutzen	Benennung	DN	PN	Dichtfläche	Position
Nozelle	Denomination	Standard	Standard	Facing	Position
					Roßabmessung Dimension

RevZ	12.01.2026	Rettel	Benker	Änderung gemäß Kundenwunsch / change according to customer request	
RevZ	16.02.2025	Eitzold	Whan	Änderung laut Kundenwunsch / Change according to customer request	
Inhalt	Datum/date	Gez./drawn	Name/name	Art der Änderung / Modification	
	10.12.2025		Altmanshofer		
Gez. / drawn	10.12.2025	Whan			
Gez. / appr.	10.12.2025	Whan			

Wasserspeicher / storage tank
 Typ RET 3000 special 1



Zeichnung Nr. / Drawing No.:	234.07-0 RevZ	Projekt Nr. / Project No.:	P2500860_1	Bestell-Nr. / Order No.:	KST1300/123853	Maßstab / Scale:	1:15	Blatt / sheet:	1/1
								Stand/as per:	12.01.2026